



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 3/15/10

Code 50.10.2.3-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)



Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title Table R602.10.2		Page 160-162
Proponent Steve Dean	Title VP Homebuilding, Ryland Homes	
Address 9025 N River Rd., Indianapolis IN 46240		Phone 317-846-3234

PROPOSED CODE CHANGE (Check One)

☒ Change to read as follows ☐ Add to read as follows ☐ Delete and substitute as follows ☐ Delete without substitution

**TABLE R602.10.2
INTERMITTENT BRACING METHODS**

METHOD	MATERIAL	MINIMUM THICKNESS	FIGURE	CONNECTION CRITERIA
GB	Gypsum board	1/2"		Nails and or screws at 7" spacing at panel edges including top and bottom plates; for all braced wall panel locations; for exterior sheathing nail or screw size, see Table R602.3(1); for interior gypsum board nail or screw size, see Table R702.3.5
PCP	Portland cement plaster	See Section R703.6 For maximum 16" spacing		1 1/2", 11 gage, 7/16" head nails at 6" spacing or 7/8" 7/16", 16 gage staples at 6" spacing

REASON AND FISCAL IMPACT

This change corrects errors in Table R602.10.2 that occurred during final correlation of the 2009 IRC. Specifically the 7/16" staple size for PCP is incorrect; Section R703.6.1 requires a 7/8" staple size.

REVIEW RECOMMENDATION

Approve

Disapprove

Approve as amended

Further Study